

1 ENLARGED PROJECTION ROOM POWER PLAN

E-318 | REF. E-311 | SCALE: 1/4" = 1'-0"



2 ENLARGED ELECTRICAL ROOM (2ND FLR) POWER PLAN

E-318 | REF. E-311 | SCALE: 1/4" = 1'-0"



3 ENLARGED EMERGENCY OPERATION CENTER 206 & EMERGENCY RESPONSE CENTER 205 POWER PLAN

E-318 | REF. E-311 | SCALE: 1/4" = 1'-0"

1/4"=1' 0 2 4 8 12

PLAN NORTH

NOTES:

1. SEE SHEET E-100 FOR SYMBOLS, ABBREVIATIONS AND GENERAL NOTES.
2. SEE SHEET E-610, E-611, AND E-612 FOR SINGLE LINE DIAGRAMS AND E-715 FOR CONDUIT AND WIRE SCHEDULES.
3. WALL MOUNTED RECEPTACLE FOR FLAT SCREEN TV. PROVIDE A DEDICATED EMERGENCY CIRCUIT FOR EACH TV AS SHOWN. COORDINATE EXACT LOCATION AND MOUNTING HEIGHT WITH ARCHITECTURAL DRAWINGS.
4. RECEPTACLES SURFACE MOUNTED ON EQUIPMENT SUPPORT SYSTEM FOR PLASMA SCREENS, COORDINATE EXACT MOUNTING HEIGHT AND LOCATION WITH ARCHITECTURAL DRAWINGS.
5. PROVIDE INSULATED GROUNDING CONDUCTOR, SIZED PER NEC, IN ALL POWER BRANCH CIRCUIT CONDUITS.
6. EQUIPMENT RACK LOCATION SHOWN ON THIS PLAN IS TO LOCATE RECEPTACLES. SEE TELECOM DRAWING (SHEET T01-02C) FOR EXACT NUMBER AND LOCATION OF RACKS.
7. COORDINATE MOUNTING HEIGHT AND EXACT LOCATION WITH ARCHITECTURAL DRAWINGS.
8. CEILING MOUNTED J-BOX TO PROVIDE POWER TO MOTORIZED SHADES, COORDINATE EXACT LOCATION WITH ARCHITECTURAL DRAWINGS. LOW VOLTAGE SWITCH FOR CONTROLS TO BE PROVIDED BY MOTORIZED SHADE MANUFACTURER, AND INSTALLED BY ELECTRICAL CONTRACTOR. PROVIDE AND INSTALL 3/4"C WITH CAT5 CABLE FROM LOW VOLTAGE SWITCH TO MOTORIZED SHADE FOR CONTROL WIRING. COORDINATE EXACT LOCATION OF LOW VOLTAGE SWITCH WITH CALTRANS/CHP PERSONNEL.

PROJECT

INLAND EMPIRE TMC — Caltrans — CHP — DISTRICT 8 / INLAND DIVISION

13892 VICTORIA STREET
FONTANA, CA 92336

CLIENT

DGS

STATE OF CALIFORNIA
DEPARTMENT OF GENERAL SERVICES
REAL ESTATE SERVICES DIVISION
PROJECT MANAGEMENT BRANCH
400 R STREET, SUITE 5100
SACRAMENTO, CA 95814
PROJECT DIRECTOR : RAFAT ALAFRANJI
TELEPHONE : (916) 376-1738

DESIGNER

DMJM H&N | AECOM

999 TOWN & COUNTRY ROAD, ORANGE CALIFORNIA 92868
T: 714-567-2400 F: 714-543-0955 www.dmjm.com

CONSULTANT

DSA STAMP

IDENTIFICATION STAMP
DIVISION OF THE STATE ARCHITECT
OFFICE OF REGULATION SERVICE

APPL. #: 04-109200-2

AC _____ FLS _____ SS _____
DATE _____

FILE NUMBER: RESD

STATUS

JULY 30, 2008

ISSUE

MARK	DATE	DESCRIPTION
C	10/27/2008	BID PERIOD ADDENDUM #5

PROJECT NO: 60004333.4000

DRAWN BY: L. DICKENS
CHECKED BY: C. DAVIES

STAMP

REGISTERED PROFESSIONAL ENGINEER — JERRY MIKOLAJ ROZICKI — No. C 24473 — Exp. 12-31-09 — STATE OF CALIFORNIA

REGISTERED PROFESSIONAL ENGINEER — CYRIL DAVIES — No. E 17631 — Exp. 09-30-09 — ELECTRICAL — STATE OF CALIFORNIA

SHEET TITLE

ENLARGED POWER PLAN

E-318

© 2003 DMJMH+N, Inc. Rev. 2003-1

DWG: Q:\Caltrans\IETMC\500 CAD\E\Sheet\E-318.dwg User: DaviesC
DATE: Oct 27, 2008 - 7:33:19 am Images:
Xrefs: "XBDR" "xIETMC-AFP02" "xIETMC-MFP02" "xIETMC-EQP02" "xIETMC-EPWE02" "xIETMC-SGRID" "xIETMC-ARC02" "IETMC_S-BLDG_rvt-1-XARC02" "IETMC_S-BLDG_rvt-1-vAFP02"