



DETAIL 1: FIRE/SMOKE DAMPER OPERATION

1. NUMEROUS MOTORIZED FIRE/SMOKE DAMPERS ARE LOCATED THROUGHOUT THE FACILITY. REFER TO MECHANICAL DRAWINGS FOR EXACT QUANTITIES AND LOCATIONS. PROVIDE AN INDIVIDUAL ADDRESSABLE CONTROL RELAY AT EACH LOCATION FOR LOCAL CONTROL OF EACH SMOKE DAMPER (i.e. BUILDING SMOKE DAMPERS OPERATED BY ZONE FROM AREA SMOKE DETECTION).
2. REFER TO FIRE ALARM RISER DIAGRAM NOTE B), SHEET FP-103.




ANN-1  
SCALE: NONE




ANN-2: GRAPHIC ANNUNCIATOR PANEL (DISPATCH/OPERATIONS)-  
SCALE: 1/16"=1'-0"

FIRE PROTECTION DRAWINGS ARE FOR PERFORMANCE/SCOPE ONLY.  
CONTRACTOR IS REQUIRED TO SUBMIT SYSTEM SHOP DRAWINGS TO  
AOR/EOR FOR REVIEW AND APPROVAL.




PROJECT




13892 VICTORIA STREET  
FONTANA, CA 92336

CLIENT



STATE OF CALIFORNIA  
DEPARTMENT OF GENERAL SERVICES  
REAL ESTATE SERVICES DIVISION  
PROJECT MANAGEMENT BRANCH  
400 R STREET, SUITE 5100  
SACRAMENTO, CA 95814  
PROJECT DIRECTOR : RAJAT ALAKRANJI  
TELEPHONE : (916) 376-1738

DESIGNER



999 TOWN & COUNTRY ROAD, ORANGE, CALIFORNIA 92668  
T: 714-567-2400 F: 714-543-0955 [www.dmjmh.com](http://www.dmjmh.com)

CONSULTANT

DSA STAMP

IDENTIFICATION STAMP  
DIVISION OF THE STATE ARCHITECT  
OFFICE OF REGULATION SERVICE

APPL. #: 04-109200-2

AC \_\_\_\_\_ FLS \_\_\_\_\_ SS \_\_\_\_\_  
DATE \_\_\_\_\_

FILE NUMBER: RESD

STATUS

JULY 30, 2008

ISSUE

MARK	DATE	DESCRIPTION
10/27/2008	10/27/2008	BID PERIOD ADDENDUM#5

PROJECT NO:

60004333.4000



DRAWN BY:

L. DICKENS

CHECKED BY:

D. WIRTZ

STAMP



SHEET TITLE

FIRE ALARM  
ANNUNCIATORS  
AND DETAILS

FP-702