ACCESSIBILITY NOTES

TITLE 24 – DISABLED ACCESS
COMMERCIAL PLAN REQUIREMENTS
(EFFECTIVE 7–1–99 ...REV 11–99)

A. SITE DEVELOPMENT & ACCESSIBLE ROUTE OF TRAVEL

NOTE: ACCESSIBLE ROUTE OF TRAVEL IS DEFINED AS "A CONTINUOUS UNOBSTRUCTED PATH CONNECTING ALL ACCESSIBLE ELEMENTS AND SPACES IN AN ACCESSIBLE BUILDING OR FACILITY THAT CAN BE NEGOTIATED BY A PERSON WITH A SEVERE DISABILITY USING A WHEELCHAIR AND THAT IS ALSO SAFE FOR AND USABLE BY PERSONS WITH OTHER DISABILITIES." SEC 1102B

NOTE: INDICATE ALL PATHS OF TRAVEL FOR DISABLED PERSONS FROM THE PUBLIC WAY AND/OR FROM THE DISABLED PARKING SPACE(S), AS REQUIRED, WITH DASHED LINES OR ARROWS.

1. SITE DEVELOPMENT AND GRADING SHALL BE DESIGNED TO PROVIDE ACCESS TO ALL ENTRANCES AND EXTERIOR GROUND FLOOR EXITS, AND ACCESS TO NORMAL PATHS OF TRAVEL, AND WHERE NECESSARY TO PROVIDE ACCESS, SHAL INCORPORATE PEDESTRIAN RAMPS, CURB RAMPS, ETC. SEC 1127B.1
2. WHEN MORE THAN ONE BUILDING OR FACILITY IS LOCATED ON A SITE, ACCESSIBLE ROUTES OF TRAVEL SHALL BE PROVIDED BETWEEN BUILDINGS AND ACCESSIBLE SITE FACILITIES. SEC 1127B.1
3. THE ACCESSIBLE ROUTE OF TRAVEL SHALL BE THE MOST PRACTICAL DIRECT ROUTE BETWEEN ACCESSIBLE BUILDING ENTRANCES, ACCESSIBLE SITE FACILITIES, AND THE ACCESSIBLE ENTRANCE TO THE SITE. SEC 1127B.1
4. AT LEAST ONE ACCESSIBLE ROUTE WITHIN THE BOUNDARY OF THE SITE SHALL BE PROVIDED FROM PUBLIC TRANSPORTATION STOPS, ACCESSIBLE PARKING AND ACCESSIBLE PASSENGER LOADING ZONES, AND PUBLIC STREETS OR SIDEWALKS, TO THE ACCESSIBLE BUILDING ENTRANCE THEY SERVE. THE ACCESSIBLE ROUTE SHALL, TO THE MAXIMUM EXTENT FEASIBLE, COINCIDE WITH THE ROUTE FOR THE GENERAL PUBLIC. SEC 1114B.1.2
5. WHEN A BUILDING OR PORTION OF A BUILDING IS REQUIRED TO BE ACCESSIBLE OR ADAPTABLE, AN ACCESSIBLE ROUTE OF TRAVEL SHALL BE PROVIDED TO ALL PORTIONS OF THE DOWN BUILDING, TO ACCESSIBLE BUILDING ENTRANCES, AND BETWEEN THE BUILDING AND THE PUBLIC WAY. SEC 1114B.1.2
6. AT LEAST ONE ACCESSIBLE ROUTE SHALL CONNECT ACCESSIBLE BUILDING OR FACILITY ENTRANCES WITH ALL ACCESSIBLE SPACES AND ELEMENTS THAT ARE ON THE SAME SITE AND WITH ALL ACCESSIBLE DWELLING UNITS WITHIN THE BUILDING OR FACILITY. SEC 1114B.1.2
7. AN ACCESSIBLE ROUTE SHALL CONNECT AT LEAST ONE ACCESSIBLE ENTRANCE OF EACH ACCESSIBLE DWELLING UNIT WITH THOSE EXTERIOR AND INTERIOR SPACES AND FACILITIES THAT SERVE THE ACCESSIBLE DWELLING UNIT. SEC 1114B.1.2
8. EXCEPT WITHIN AN INDIVIDUAL DWELLING UNIT, AN ACCESSIBLE ROUTE OF TRAVEL SHALL NOT PASS THROUGH KITCHENS, STORAGE ROOMS, RESTROOMS, CLOSETS, OR OTHER SPACES USED FOR SIMILAR PURPOSES. SEC 1114B.1.2
9. WHEN MORE THAN ONE ROUTE OF TRAVEL IS PROVIDED, ALL ROUTES SHALL BE ACCESSIBLE. SEC 1114B.1.2

B. WALKS & SIDEWALKS

1. WALKS AND SIDEWALKS SHALL HAVE A CONTINUOUS COMMON SURFACE, NOT INTERRUPTED BY STEPS OR BY ABRUPT CHANGES IN LEVEL EXCEEDING 1/2", AND SHALL BE A MINIMUM OF 48" IN WIDTH. SEC 1133B.7.1. FIG 11B–27(A).
2. WHEN ABRUPT CHANGES IN LEVEL NOT EXCEEDING 1/2" OCCUR, THEY SHALL BE BEVELED WITH A SLOPE NO GREATER THAN 1:2, EXCEPT THAT LEVEL CHANGES NOT EXCEEDING 1/4" MAY BE VERTICAL. SEC 1133B.7.4. FIG 11B–5E(C) & (D).
3. ABRUPT CHANGES IN LEVEL ALONG ANY ACCESSIBLE ROUTE EXCEEDING 1/2" SHALL COMPLY WITH THE REQUIREMENTS FOR CURB RAMPS. SEC 1133B.7.4
4. WHEN THE SLOPE IN THE DIRECTION OF TRAVEL OF ANY WALK EXCEEDS 1 VERTICAL TO 20 HORIZONTAL IT SHALL COMPLY WITH THE PROVISIONS OF SECTION 1133B.5 AS A PEDESTRIAN RAMP. SEC 1133B.7.3
5. WALK AND SIDEWALK SURFACE CROSS SLOPES SHALL NOT EXCEED 1/4" PER FOOT EXCEPT WHEN THE ENFORCING AGENCY FINDS THAT DUE TO LOCAL CONDITIONS IT CREATES AN UNREASONABLE HARDSHIP, THE SLOPE CAN BE INCREASED TO A MAXIMUM OF 1/2" PER FOOT FOR DISTANCES NOT TO EXCEED 20'. SEC 1133B.7.1.3
6. WALKS SHALL BE PROVIDED WITH A LEVEL AREA NOT LESS THAN 60" BY 60" AT A DOOR OR GATE THAT SWINGS TOWARD THE WALK, AND NOT LESS THAN 48" WIDE OR 24" DEEP AT A DOOR OR GATE THAT SWINGS AWAY FROM THE WALK. SEC 1133B.7.5
7. WALKS SHALL EXTEND A MINIMUM OF 24" TO THE SIDE OF THE STRIKE EDGE OF A DOOR OR GATE THAT SWINGS TOWARD THE WALK. SEC 1023.5 [3324(E)].
8. ALL WALKS WITH CONTINUOUS GRADIENTS SHALL HAVE LEVEL AREAS AT LEAST 5' IN LENGTH AT INTERVALS OF AT LEAST EVERY 400'. SEC 1133B.7.6
9. WALK AND SIDEWALK SURFACES SHALL BE SLIP–RESISTANT AS FOLLOWS: SEC 1133B.7.1
   a. SURFACES WITH A SLOPE OF LESS THAN 6% GRADIENT SHALL BE AT LEAST AS SLIP–RESISTANT AS THAT DESCRIBED AS A MEDIUM SATEED FINISH.
   b. SURFACES WITH A SLOPE OF 6% GRADIENT SHALL BE SLIP–RESISTANT.
10. WALKS, SIDEWALKS, AND PEDESTRIAN WAYS SHALL BE FREE OF GRATINGS WHENEVER POSSIBLE. FOR GRATINGS LOCATED IN THE SURFACE OF ANY OF THESE AREAS, GRID OPENINGS IN GRATINGS SHALL BE NO GREATER THAN 1/2" WIDE IN ONE DIRECTION. IF GRATINGS HAVE ELONGATED OPENINGS, THEY SHALL BE PLACED SO THAT THE LONG DIMENSION IS PERPENDICULAR TO THE DOMINANT DIRECTION OF TRAVEL. SEC 1124B.4 & 1133B.7.2. FIG 11B–7B(A).

C. RAMPS

NOTE: ANY PATH OF TRAVEL SHALL BE CONSIDERED A RAMP IF IT'S SLOPE IS GREATER THAN 1' RISE IN 20' OF HORIZONTAL RUN. SEC 1133B.5.1

1. THE MAXIMUM SLOPE OF A RAMP THAT SERVES ANY EXITWAY, PROVIDES ACCESS FOR PERSONS WITH DISABILITIES, OR IS IN THE PATH OF TRAVEL SHALL BE 1' RISE IN 12' OF HORIZONTAL RUN. SEC 1133B.5.3
2. THE CROSS SLOPE OF RAMP SURFACES SHALL BE NO GREATER THAN 1:50. SEC 1133B.5.3
3. THE WIDTH OF RAMPS SHALL BE AS REQUIRED FOR STAIRWAYS AND EXITS. SEC 1133B.5.2. FIG 11B–38 & 39.
4. PEDESTRIAN RAMPS SERVING PRIMARY ENTRANCES TO BUILDINGS HAVING AN OCCUPANT LOAD OF 300 OR MORE SHALL HAVE A MINIMUM CLEAR WIDTH OF 60". SEC 1133B.5.2.2
5. RAMPS SERVING GROUP R OCCUPANCIES MAY BE 36" CLEAR WIDTH WHEN THE OCCUPANT LOAD IS 50 OR LESS. SEC 1133B.5.2.2
6. ALL OTHER PEDESTRIAN RAMPS SERVING PRIMARY ENTRANCES SHALL HAVE A MINIMUM WIDTH OF 48". SEC 1133B.5.2.2
7. LANDINGS SHALL BE PROVIDED AT THE TOP AND BOTTOM OF EACH RAMP. SEC 1133B.5.4.1 & 1003.3.4.4. FIG 11B–38 & 39.
8. INTERMEDIATE LANDINGS SHALL BE PROVIDED AT INTERVALS NOT EXCEEDING 30" OF VERTICAL RISE AND AT EACH CHANGE OF DIRECTION. SEC 1133B.5.4.1. FIG 11B–38 & 39.
9. TOP LANDINGS SHALL BE NOT LESS THAN 60" WIDE AND SHALL HAVE A LENGTH OF NOT LESS THAN 60" IN THE DIRECTION OF RAMP RUN. SEC 1133B.5.4.2 & 1003.3.4.4. FIG 11B–38 & 39
10. DOORS IN ANY POSITION SHALL NOT REDUCE THE MINIMUM DIMENSION OF THE RAMP LANDING TO LESS THAN 42" AND SHALL NOT REDUCE THE REQUIRED WIDTH BY MORE THAN 3" WHEN FULLY OPEN. SEC 1133B.5.4.3 & 1003.3.4.4. FIG 11B–38 & 39.
11. THE WIDTH OF THE LANDING SHALL EXTEND 24" PAST THE STRIKE EDGE OF ANY DOOR OR GATE FOR EXTERIOR RAMPS AND 18" PAST THE STRIKE EDGE FOR INTERIOR RAMPS. SEC 1133B.5.4.4 & 1003.3.4.4. FIG 11B–39.
12. AT BOTTOM AND INTERMEDIATE LANDINGS, THE WIDTH SHALL BE AT LEAST THE SAME AS REQUIRED FOR THE RAMP. SEC 1133B.5.4.5. FIG 11B–38 & 39.
13. INTERMEDIATE LANDING AT A CHANGE OF DIRECTION IN EXCESS OF 30 DEGREES AND BOTTOM LANDINGS SHALL HAVE A DIMENSION IN THE DIRECTION OF RAMP RUN OF NOT LESS THAN 72" TO ACCOMMODATE THE HANDRAIL EXTENSION. SEC 1133B.5.4.6 & 1003.3.4.4. FIG 11B–38 & 39.
14. OTHER INTERMEDIATE LANDINGS SHALL HAVE A DIMENSION IN THE DIRECTION OF RAMP RUN OF NOT LESS THAN 60". SEC 1133B.5.4.7. FIG 11B–38.
15. RAMP LANDINGS ARE NOT CONSIDERED IN DETERMINING THE MAXIMUM HORIZONTAL DISTANCE OF EACH RAMP. SEC 1133B.5.4.1
16. HANDRAILS ARE REQUIRED ON RAMPS THAT PROVIDE ACCESS IF THE RAMP SLOPE EXCEEDS 1' RISE IN 20' OF HORIZONTAL RUN, EXCEPT THAT AT EXTERIOR DOOR LANDINGS, HANDRAILS ARE NOT REQUIRED ON RAMPS LESS THAN 6" RISE OR 72" IN LENGTH. SEC 1133B.5.5.1
17. HANDRAILS SHALL BE PLACED ON EACH SIDE OF EACH RAMP, SHALL BE CONTINUOUS THE FULL LENGTH OF THE RAMP, SHALL BE 34" TO 38" ABOVE THE RAMP SURFACE, SHALL EXTEND A MINIMUM OF 1' BEYOND THE TOP AND BOTTOM OF THE RAMP, AND THE ENDS SHALL BE RETURNED. SEC 1133B.5.5.1. FIG 11B–27(B) & (C)
18. THE GRIP PORTION OF HANDRAILS SHALL BE NOT LESS THAN 1–1/4" NOR MORE THAN 1–1/2". OR THE SHAPE SHALL PROVIDE AN EQUIVALENT GRIPPING SURFACE, AND ALL SURFACES SHALL BE SMOOTH WITH NO SHARP CORNERS. HANDRAILS SHALL NOT ROTATE WITHIN THEIR FITTINGS. SEC 1133B.5.5.1. FIG 11B–36.
19. HANDRAILS PROJECTING FROM A WALL SHALL HAVE A SPACE OF 1–1/2" BETWEEN THE WALL AND THE HANDRAIL. SEC 1133B.5.5.1. FIG 11B–36.
20. HANDRAILS MAY BE LOCATED IN A RECESS IF THE RECESS IS A MAXIMUM OF 3" DEEP AND EXTENDS AT LEAST 18" ABOVE THE TOP OF THE RAIL. SEC 1133B.5.5.1. FIG 11B–36.
21. ANY WALL OR OTHER SURFACE ADJACENT TO HANDRAILS SHALL BE FREE OF SHARP OR ABRASIVE ELEMENTS. EDGES SHALL HAVE A MINIMUM RADIUS OF 1/8". SEC 1007.5A[3307(E.1)]. FIG 11B–36.
22. WHERE THE RAMP LANDING IS NOT BOUNDED BY A WALL OR FENCE, THERE SHALL BE PROVIDED ON EACH SIDE OF THE RAMP LANDING WHERE THERE IS A VERTICAL DROP EXCEEDING 4", ONE OF THE FOLLOWING: SEC 1133B.5.4.9. FIG 11B–27(B) & (C).
   a. A GUIDE CURB, A MINIMUM OF 2" IN HEIGHT; OR
   b. A WHEEL GUIDE RAIL, CENTERED 3" ±1" ABOVE THE SURFACE OF THE RAMP LANDING.
23. WHERE THE RAMP SURFACE IS NOT BOUNDED BY A WALL OR FENCE AND THE RAMP EXCEEDS 10' IN LENGTH, THE RAMP SHALL COMPLY WITH ONE OF THE FOLLOWING REQUIREMENTS: SEC 1133B.5.6. FIG 11B–27(B) & (C).
   a. A GUIDE CURB A MINIMUM OF 2" IN HEIGHT SHALL BE PROVIDED AT EACH SIDE OF THE RAMP; OR
   b. A WHEEL GUIDE RAIL SHALL BE PROVIDED, CENTERED 3" ±1" ABOVE THE SURFACE OF THE RAMP.
24. OUTDOOR RAMPS AND THEIR APPROACHES SHALL BE DESIGNED AND CONSTRUCTED SO THAT WATER WILL NOT ACCUMULATE ON WALKING SURFACES. SEC 1133B.5.7

D. CURB RAMPS

NOTE: CURB RAMPS SHALL BE CONSTRUCTED AT EACH CORNER OF STREET INTERSECTIONS AND WHERE A PEDESTRIAN WAY CROSSES A CURB. THE PREFERRED AND RECOMMENDED LOCATION FOR CURB RAMPS IS IN THE CENTER OF THE CROSSWALK OF EACH STREET CORNER. WHERE IT IS NECESSARY TO LOCATE A CURB RAMP IN THE CENTER OF THE CURB RETURN AND THE STREET SURFACES ARE MARKED TO IDENTIFY PEDESTRIAN CROSSWALKS, THE LOWER END OF THE CURB RAMP SHALL TERMINATE WITHIN SUCH CROSSWALK AREAS. SEC 1127B.5.1. FIG 11B–19 THROUGH 11B–23.

1. PROVIDE A CURB RAMP AT HANDICAPPED PARKING. SEC 1127B.5.1
2. CURB RAMPS SHALL BE A MINIMUM OF 4' IN WIDTH AND SHALL LIE, GENERALLY, IN A SINGLE SLOPED PLANE, WITH A MINIMUM OF SURFACE WARPING AND CROSS SLOPE. SEC 1127B.5.2
3. THE SLOPE OF CURB RAMPS SHALL NOT EXCEED 1 VERTICAL TO 12 HORIZONTAL. SEC 1127B.5.3
4. MAXIMUM SLOPES OF ADJOINING GUTTERS, ROAD SURFACE IMMEDIATELY ADJACENT TO THE CURB RAMP, OR ACCESSIBLE ROUTE, SHALL NOT EXCEED 1:20 WITHIN 4' OF THE TOP AND BOTTOM OF THE CURB RAMP. THE SLOPE OF THE FANNED OR FLARED SIDES OF CURB RAMPS SHALL NOT EXCEED 1 UNIT VERTICAL TO 10 UNITS HORIZONTAL. SEC 1127B.5.3
5. A LEVEL LANDING 4' DEEP SHALL BE PROVIDED AT THE UPPER END OF EACH CURB RAMP. OVER ITS FULL WIDTH TO PERMIT SAFE EGRESS FROM THE RAMP SURFACE, OR THE SLOPE OF THE FANNED OR FLARED SIDES OF THE CURB RAMP SHALL NOT EXCEED 1 VERTICAL TO 12 HORIZONTAL. SEC 1127B.5.4
6. TRANSITIONS FROM RAMPS TO WALKS, GUTTERS, OR STREETS SHALL BE FLUSH AND FREE OF ABRUPT CHANGES. SEC 1127B.5.3
7. IF DIAGONAL (CORNER TYPE) CURB RAMPS HAVE RETURNED CURBS OR OTHER WELL DEFINED EDGES, SUCH EDGES SHALL BE PARALLEL TO THE DIRECTION OF PEDESTRIAN FLOW. THE BOTTOM OF DIAGONAL CURB RAMPS SHALL HAVE 48" MINIMUM CLEAR SPACE. IF DIAGONAL CURB RAMPS ARE PROVIDED AT MARKED CROSSINGS, THE 48" CLEAR SPACE SHALL BE WITHIN THE MARKINGS. IF DIAGONAL CURB RAMPS HAVE FLARED SIDES, THEY SHALL ALSO HAVE AT LEAST A 24" LONG SEGMENT OF STRAIGHT CURB LOCATED ON EACH SIDE OF THE CURB RAMP AND WITHIN THE MARKED CROSSING. SEC 1127B.5.10
8. THE SURFACE OF EACH CURB RAMP AND ITS FLARED SIDES SHALL BE STABLE, FIRM, AND SLIP–RESISTANT AND SHALL BE OF CONTRASTING FINISH FROM THAT OF THE ADJACENT SIDEWALK. SEC 1127B.5.6
9. ALL CURB RAMPS SHALL HAVE A GROOVED BORDER 12" WIDE AT THE LEVEL SURFACE OF THE SIDEWALK ALONG THE TOP AND EACH SIDE APPROXIMATELY 3/4" ON CENTER. ALL CURB RAMPS CONSTRUCTED BETWEEN THE FACE OF THE CURB AND THE STREET SHALL HAVE A GROOVED BORDER AT THE LEVEL SURFACE OF THE SIDEWALK. SEC 1127B.5.7
10. THE LOWER END OF EACH CURB RAMP SHALL HAVE A 1/2" LIP BEVELED AT 45 DEGREES AS A DETECTABLE WAY–FINDING EDGE FOR PERSONS WITH VISUAL IMPAIRMENTS. SEC 1127B.5.5
11. A CURB RAMP SHALL HAVE A DETECTABLE WARNING THAT EXTENDS THE FULL WIDTH AND DEPTH OF THE CURB RAMP INSIDE THE GROOVED BORDER WHEN THE RAMP SLOPE IS LESS THAN 1 VERTICAL TO 15 HORIZONTAL. DETECTABLE WARNINGS SHALL CONSIST OF RAISED TRUNCATED DOMES WITH A DIAMETER OF NOMINAL 0.9" AT THE BASE TAPERING TO 0.45" AT THE TOP, A HEIGHT OF NOMINAL 0.2", AND A CENTER–TO–CENTER SPACING OF NOMINAL 2.35", IN COMPLIANCE WITH FIGURE 11B–23A. "NOMINAL", AS USED HERE, SHALL BE IN ACCORDANCE WITH SECTION 12–31–102, STATE REFERENCED STANDARDS CODE. THE DETECTABLE WARNING SHALL CONTRAST VISUALLY WITH ADJOINING SURFACES, EITHER LIGHT–ON–DARK OR DARK–ON–LIGHT. THE MATERIAL USED TO PROVIDE CONTRAST SHALL BE AN INTEGRAL PART OF THE WALKING SURFACE. THE DOMES MAY BE CONSTRUCTED IN A VARIETY OF METHODS, INCLUDING CAST–IN–PLACE OR STAMPED, OR MAY BE PART OF A PREFABRICATED SURFACE TREATMENT. SEC 1127B.5.8
12. CURB RAMPS SHALL BE LOCATED OR PROTECTED TO PREVENT THEIR OBSTRUCTION BY PARKED CARS SEC 1127B.5.9

E. PARKING

1. PROVIDE DISABLED PARKING SPACES AS REQUIRED BY TABLE 11B–6. SEC 1129B.1

TABLE 11B–6

TOTAL # OF PARKING SPACES PROVIDED	TOTAL # OF DISABLED SPACES REQUIRED
1–25	1
26–50	2
51–75	3
76–100	4
101–150	5
151–200	6
201–300	7
301–400	8
401–500	9
501–1000	2% OF TOTAL
1001 & OVER	20+1 FOR EACH 100 OR FRACTION THEREOF OVER 1001

2. AT FACILITIES PROVIDING MEDICAL CARE AND OTHER SERVICES FOR PERSONS WITH MOBILITY IMPAIRMENTS, PARKING SPACES COMPLYING WITH SECTION 1129B SHALL BE PROVIDED IN ACCORDANCE WITH TABLE 11B–6 EXCEPT AS FOLLOWS: SEC 1129B.3
   a. OUTPATIENT UNITS AND FACILITIES: 10% OF THE TOTAL NUMBER OF PARKING SPACES PROVIDED SERVING EACH SUCH OUTPATIENT UNIT OR FACILITY; SEC 1129B.3.1
   b. UNITS AND FACILITIES THAT SPECIALIZE IN TREATMENT OR SERVICES FOR PERSONS WITH MOBILITY IMPAIRMENTS: 20% OF THE TOTAL NUMBER OF PARKING SPACES PROVIDED SERVING EACH SUCH UNIT OR FACILITY. SEC 1129B.3.2
3. EACH LOT OR PARKING STRUCTURE WHERE PARKING IS PROVIDED FOR THE PUBLIC AS CLIENTES, GUESTS OR EMPLOYEES, SHALL PROVIDE ACCESSIBLE PARKING AS REQUIRED BY SECTION 1129B. SEC 1129B.1
4. ACCESSIBLE PARKING SPACES SERVING A PARTICULAR BUILDING SHALL BE LOCATED AS NEAR AS PRACTICAL TO A PRIMARY ENTRANCE AND ON THE SHORTEST ACCESSIBLE ROUTE OF TRAVEL FROM ADJACENT PARKING TO AN ACCESSIBLE ENTRANCE. SEC 1129B.1 & 1129B.4
5. IN PARKING FACILITIES THAT DO NOT SERVE A PARTICULAR BUILDING, ACCESSIBLE PARKING SHALL BE LOCATED ON THE SHORTEST ACCESSIBLE ROUTE OF TRAVEL TO AN ACCESSIBLE PEDESTRIAN ENTRANCE OF THE PARKING FACILITY. SEC 1129B.1
6. IN BUILDINGS WITH MULTIPLE ACCESSIBLE ENTRANCES WITH ADJACENT PARKING, ACCESSIBLE PARKING SPACES SHALL BE DISPERSED AND LOCATED CLOSEST TO THE ACCESSIBLE ENTRANCES. SEC. 1129B.1
7. WHERE SINGLE ACCESSIBLE PARKING SPACES ARE PROVIDED, THEY SHALL BE 14' WIDE AND OUTLINED TO PROVIDE A 9' PARKING AREA AND A 5' LOADING AND UNLOADING ACCESS AISLE ON THE PASSENGER SIDE OF THE VEHICLE. SEC 1129B.4.1. FIG 11B–18B.
8. WHEN MORE THAN ONE ACCESSIBLE PARKING SPACE IS PROVIDED, IN LIEU OF PROVIDING A 14' WIDE SPACE FOR EACH PARKING SPACE, TWO SPACES CAN BE PROVIDED WITHIN A 23' WIDE AREA LINED TO PROVIDE A 9' PARKING AREA ON EACH SIDE OF A 5' LOADING AND UNLOADING ACCESS AISLE IN THE CENTER. SEC 1129B.4.1. FIG 11B–18A & C.
9. THE MINIMUM LENGTH OF AN ACCESSIBLE PARKING SPACE SHALL BE 18'. SEC 1129B.4.1. FIG 11B–18A, B & C.
10. WHEN LESS THAN 5 PARKING SPACES ARE PROVIDED AT BUILDINGS AND FACILITIES SUBJECT TO THESE REGULATIONS, ONE SHALL BE 14' WIDE AND OUTLINED TO PROVIDE A 9' PARKING AREA AND A 5' LOADING AND UNLOADING AREA. HOWEVER, THERE IS NO REQUIREMENT THAT THE SPACE BE RESERVED EXCLUSIVELY OR IDENTIFIED FOR USE BY PERSONS WITH DISABILITIES ONLY. SEC 1129B.2
11. ONE IN EVERY EIGHT ACCESSIBLE SPACES, BUT NOT LESS THAN ONE, SHALL BE SERVED BY AN ACCESS AISLE 96" WIDE MINIMUM AND SHALL BE DESIGNATED VAN ACCESSIBLE. ALL SUCH SPACES MAY BE GROUPED ON ONE LEVEL OF A PARKING STRUCTURE. SEC 1129B.4.2
12. SURFACE SLOPES OF ACCESSIBLE PARKING SPACES SHALL BE THE MINIMUM POSSIBLE AND SHALL NOT EXCEED 1 UNIT VERTICAL TO 50 UNITS HORIZONTAL IN ANY DIRECTION. SEC 1129B.4.4
13. ALL ENTRANCES TO AND VERTICAL CLEARANCES WITHIN PARKING STRUCTURES SHALL HAVE A MINIMUM VERTICAL CLEARANCE OF 8'–2" WHERE NECESSARY FOR ACCESSIBILITY TO ACCESSIBLE PARKING SPACES. THE VERTICAL CLEARANCE SHALL BE CLEAR OF ALL OBSTRUCTIONS, INCLUDING BEAMS, SPRINKLER HEADS, WATER AND SEWER PIPING, ETC. SEC 1130B
14. IN EACH PARKING AREA, A BUMPER OR CURB SHALL BE PROVIDED AND LOCATED TO PREVENT ENCROACHMENT OF CARS OVER THE REQUIRED WIDTH OF WALKWAYS. SEC 1129B.4.3. FIG 11B–18A, B & C.
15. PEDESTRIAN WAYS WHICH ARE ACCESSIBLE TO PEOPLE WITH DISABILITIES SHALL BE PROVIDED FROM EACH SUCH PARKING SPACE TO ACCESSIBLE FACILITIES, INCLUDING CURB CUTS OR RAMPS AS NEEDED. SEC 1129B.4.3. FIG 11B–18A, B & C.
16. RAMPS SHALL NOT ENCROACH INTO ANY PARKING SPACE, WITH THE EXCEPTION OF A TRANSITION RAMP FROM A LOADING/UNLOADING AREA TO AN ADJACENT SIDEWALK. THE TRANSITION RAMP SHALL BE A MINIMUM OF 48" IN WIDTH, A MAXIMUM OF 60" IN LENGTH, WITH A MAXIMUM SLOPE OF 1:12. SEC 1129B.4.3. FIG 11B–18A, B & C.
17. ACCESSIBLE PARKING SPACES SHALL BE SO LOCATED THAT PERSONS WITH DISABILITIES ARE NOT COMPELLED TO WALK OR WALK BEHIND PARKED CARS OTHER THAN THEIR OWN. SEC 1129B.4.3
18. EACH PARKING SPACE RESERVED FOR PERSONS WITH DISABILITIES SHALL BE IDENTIFIED BY A REFLECTORIZED SIGN PERMANENTLY POSTED IMMEDIATELY ADJACENT TO AND VISIBLE FROM EACH STALL OR SPACE, CONSISTING OF A PROFILE VIEW OF A WHEELCHAIR WITH OCCUPANT IN WHITE ON DARK BLUE BACKGROUND. THE SIGN SHALL NOT BE SMALLER THAN 70 SQUARE INCHES IN AREA AND, WHEN IN A PATH OF TRAVEL, SHALL BE POSTED AT A MINIMUM HEIGHT OF 80" FROM THE BOTTOM OF THE SIGN TO THE PARKING SPACE FINISHED GRADE. SEC 1129B.5. FIG 11B–18A, B & C.
19. SIGNS TO IDENTIFY ACCESSIBLE PARKING SPACES MAY BE CENTERED ON THE WALL AT THE INTERIOR END OF THE PARKING SPACE AT A MINIMUM HEIGHT OF 36" FROM THE PARKING SPACE FINISHED GRADE, GROUND OR SIDEWALK. SEC 1129B.5
20. VAN ACCESSIBLE PARKING SPACES SHALL HAVE AN ADDITIONAL SIGN STATING "VAN–ACCESSIBLE" MOUNTED BELOW THE SYMBOL OF ACCESSIBILITY AND POSTED AT A MINIMUM HEIGHT OF 80" FROM THE BOTTOM OF THE SIGN TO THE PARKING SPACE FINISHED GRADE. SEC 1129B.5
21. AN ADDITIONAL SIGN SHALL ALSO BE POSTED, IN A CONSPICUOUS PLACE, AT EACH ENTRANCE TO OFF–STREET PARKING FACILITIES, OR IMMEDIATELY ADJACENT TO AND VISIBLE FROM EACH STALL OR SPACE. THE SIGN SHALL BE NOT LESS THAN 17" BY 22" IN SIZE WITH LETTERING NOT LESS THAN 1" IN HEIGHT, WHICH CLEARLY AND CONSPICUOUSLY STATES THE FOLLOWING: SEC 1129B.5

"UNAUTHORIZED VEHICLES PARKED IN DESIGNATED ACCESSIBLE SPACES NOT DISPLAYING DISTINGUISHING PLACARDS OR LICENSE PLATES ISSUED FOR PERSONS WITH DISABILITIES MAY BE TOWED AWAY AT OWNER'S EXPENSE. TOWED VEHICLES MAY BE RECLAIMED AT _____ OR BY TELEPHONING _____"

NOTE: BLANK SPACES ARE TO BE FILLED IN WITH APPROPRIATE INFORMATION AS A PERMANENT PART OF THE SIGN.

22. THE SURFACE OF EACH ACCESSIBLE PARKING SPACE OR STALL SHALL HAVE A SURFACE IDENTIFICATION DUPLICATING EITHER OF THE FOLLOWING SCHEMES: SEC 1129B.5. FIG 11B–18A, B & C.
   a. BY OUTLINING OR PAINTING THE STALL OR SPACE IN BLUE AND OUTLINING ON THE GROUND IN THE STALL OR SPACE IN WHITE OR SUITABLE CONTRASTING COLOR A PROFILE VIEW DEPICTING A WHEELCHAIR WITH OCCUPANT; OR
   b. BY OUTLINING A PROFILE VIEW OF A WHEELCHAIR WITH OCCUPANT IN WHITE ON BLUE BACKGROUND. THE PROFILE VIEW SHALL BE LOCATED SO THAT IT IS VISIBLE TO A TRAFFIC ENFORCEMENT OFFICER WHEN A VEHICLE IS PROPERLY PARKED IN THE SPACE AND SHALL BE 36" HIGH BY 36" WIDE.

F. PASSENGER DROP–OFF & LOADING ZONES

(NOT APPLICABLE)

G. PEDESTRIAN GRADE SEPARATIONS

(NOT APPLICABLE)

H. ENTRANCES & EXITS

NOTE: EXITS IN EXCESS OF THOSE REQUIRED BY SECTION 1114B.2.1 AND WHICH ARE MORE THAN 24" ABOVE GRADE ARE NOT REQUIRED TO BE ACCESSIBLE. SUCH DOORS SHALL HAVE SIGNS WARNING THAT THEY ARE NOT ACCESSIBLE. WARNINGS SIGNS SHALL COMPLY WITH SECTION 1117B.5. SEC 1133B.1.1.1.1 EXC.2

1. FOR THE PURPOSES OF TITLE 24, THE USE OF THE TERM EXIT DOOR APPLIES TO ALL DOORS THAT PROVIDE ACCESS, THAT IS, ENTRANCES, PASSAGE DOORS, ETC.
2. ALL ENTRANCES AND ALL EXTERIOR GROUND FLOOR EXIT DOORS TO BUILDINGS AND FACILITIES SHALL BE MADE ACCESSIBLE TO PERSONS WITH DISABILITIES. SEC 1114B.1.3 & 1133B.1.1.1.1
3. REVOLVING DOORS SHALL NOT BE USED AS A REQUIRED ENTRANCE FOR PERSONS WITH DISABILITIES. SEC 1133B.2.3.
4. DURING PERIODS OF PARTIAL OR RESTRICTED USE OF A BUILDING OR FACILITY, THE ENTRANCES USED FROM PRIMARY ACCESS SHALL BE ACCESSIBLE TO AND USABLE BY PERSONS WITH DISABILITIES. SEC 1133B.1.1.1.2
5. EXIT DOORS SHALL BE OPENABLE FROM THE INSIDE WITHOUT THE USE OF A KEY, TOOL, OR ANY SPECIAL KNOWLEDGE OR EFFORT. SEC 1003.3.1.8
6. BARS, GRILLES, GRATES, OR SIMILAR DEVICES PLACED OVER EXIT DOORS, SHALL BE OPENABLE FROM THE INSIDE WITHOUT THE USE OF A KEY, TOOL, OR ANY SPECIAL KNOWLEDGE OR OR EFFORT. SUCH BARS, GRILLES, GRATES, OR SIMILAR DEVICES SHALL BE EQUIPPED WITH AN APPROVED RELEASE DEVICE FOR USE BY THE FIRE DEPARTMENT ONLY, ON THE EXTERIOR SIDE FOR THE PURPOSE OF FIRE DEPARTMENT EMERGENCY ACCESS, WHEN REQUIRED BY THE AUTHORITY HAVING JURISDICTION. SEC 1003.3.1.8
7. MANUALLY OPERATED EDGE– OR SURFACE–MOUNTED FLUSH BOLTS AND SURFACE BOLTS OR ANY OTHER TYPE OF DEVICE THAT MAY BE USED TO CLOSE OR RESTRAIN THE DOOR OTHER THAN BY OPERATION OF THE LOCKING DEVICE SHALL NOT BE USED. WHERE EXIT DOORS ARE USED IN PAIRS AND APPROVED AUTOMATIC FLUSH BOLTS ARE USED, THE DOOR LEAF HAVING THE AUTOMATIC FLUSH BOLTS SHALL HAVE NO DOORKNOB OR SURFACE–MOUNTED HARDWARE. THE UNLATCHING OF ANY LEAF SHALL NOT REQUIRE MORE THAN ONE OPERATION. SEC 1003.3.1.8
8. LATCHING AND LOCKING DOORS THAT ARE HAND ACTIVATED AND WHICH ARE IN A PATH OF TRAVEL SHALL BE OPERABLE WITH A SINGLE EFFORT BY LEVER TYPE HARDWARE, PANIC BARS, PUSH–PULL ACTIVATING BARS, OR OTHER HARDWARE DESIGNED TO PROVIDE PASSAGE WITHOUT REQUIRING THE ABILITY TO GRASP THE OPENING HARDWARE OR TWISTING OF THE WRIST. THE DOOR SHALL OPERATE AS ABOVE IN EGRESS DIRECTION. SEC 1133B.2.5.1
9. DOORS TO INDIVIDUAL HOTEL OR MOTEL UNITS SHALL OPERATE SIMILARLY TO THE REQUIREMENTS OF SEC 1133B.2.5.1, EXCEPT THAT WHEN BOLT AND UNLATCHING OPERATION IS KEY OPERATED FROM CORRIDOR OR EXTERIOR SIDE OF THE DOOR, LARGE BOW KEYS 2" (FULL BOW) OR 1–1/4" (HALF BOW) SHALL BE PROVIDED IN LIEU OF LEVER TYPE HARDWARE ON THE CORRIDOR SIDE. SEPARATE DEADLOCK ACTIVATION ON ROOM SIDE OF CORRIDOR DOORS IN HOTELS THE CLEAR WIDTH OF THE EXIT WITH LEVER HANDLE OR LARGE THUMB TURN IN AN EASILY REACHED LOCATION. SEC 1133B.2.5.1
10. HAND–ACTIVATED DOOR OPENING HARDWARE SHALL BE CENTERED BETWEEN 30" AND 44" ABOVE THE FLOOR. SEC 1133B.2.5.1
11. EVERY DOORWAY WHICH IS LOCATED WITHIN AN ACCESSIBLE PATH OF TRAVEL SHALL BE OF A SIZE AS TO PERMIT THE INSTALLATION OF A DOOR NOT LESS THAN 3' IN WIDTH AND NOT LESS THAN 6'–8" IN HEIGHT. WHEN INSTALLED, EXIT DOORS