

KEYNOTES

1. 2"ø INSULATED HEATING HOT WATER SUPPLY AND RETURN PIPING THRU WALL TO BOILER ON ROOF. SEE DWG M-2.2.3 FOR CONTINUATION. SEE PIPING DIAGRAM 1/M-3.2
2. VAV BOX ABOVE CEILING (TYP.). SEE DETAIL 2/M-3.1
3. CONNECT HWS AND HWR BRANCH PIPING TO REHEAT COIL IN VAV BOX (TYP.). SEE DETAIL 3/M-3.1
4. FAN COIL UNIT ON WALL. SEE DETAIL 4/M-3.2
5. FAN COIL UNIT BELOW ROOF. SEE DETAIL 10/M-3.1
6. ⅜" REFRIGERANT LIQUID AND INSULATED ⅝" SUCTION PIPING TO CONDENSING UNIT ON ROOF.
7. LINE SIZE SHUT-OFF VALVE.
8. SEE PIPE SUPPORT DETAIL 6/M-3.2

KEY PLAN



BUILDING 2 - MECHANICAL PIPING PLAN | SCALE: 1/8"=1'-0" | 1

0742 COUNTY OF ORANGE HEALTH CARE AGENCY 401 SOUTH TUSTIN STREET

County of Orange
OC PUBLIC WORKS
Architecture & Engineering

Sym.	Descrip.	Date	By

Revisions 0742

Consultants
FTA Fire Protection Engineering
Licensed AA/DB
Professional Engineer
Fire Protection Engineering
Irvine, CA 92606
Tel: 949-955-1818
Fax: 714-505-5648
Job: 09-0-0-0-0-0-0-0-0

Drawn ML | Chkd. | 11-26-09 Date

A-E Seal

A-E ALEXANDER + HIBBS, AIA, INC.
ALEXANDER + HIBBS, AIA, INC.
Architecture and Planning
1000 E. Santa Clara Ave. A
Santa Ana, California
92705
Tel: 714.730.0300

Design | Chkd. | Date Nov. 25, 2009

Sht Title BUILDING 2 - MECHANICAL PIPING PLAN
Project COUNTY OF ORANGE HEALTH CARE AGENCY
401 SOUTH TUSTIN STREET
401 SOUTH TUSTIN STREET
ORANGE, CA 92866
PROJ. NO. 100-042-P210-4200

Plan No.
52333-03608

Sheet
M-2.2.2