LIGHT FIXTURE SCHEDULE

FIXTURE TYPE	FIXTURE SYMBOL	MANUFACTURER	CATALOG NUMBER	WATTS	VOLTS	MTG	LAMP TYPE	REMARKS
A		H.E WILLIAMS INC	D5PG-S22-41T-WP-EQ-EBLW2/2*OS-277	69	277	CR	4-F17W T8 35K FLUORESCENT	
B		H.E WILLIAMS INC	50G-S22-232U-FA12125-EQ-EBLW2*OS277	62	277	CR	2-32W U T8 35K FLUORESCENT	
C		H.E WILLIAMS INC	50F-S22-232U-FA12125-EQ-EBLW2*OS277	62	277	CR	2-32W U T8 35K FLUORESCENT	
D		H.E WILLIAMS INC	50G-S24-232-FA12125-EQ-EBLW/2*OS-277	62	277	CR	2-32W T8 35K FLUORESCENT	
E		H.E WILLIAMS INC	50G-S24-332-FA12125-EQ-EBLW2/1*OS-277	93	277	CR	3-32W T8 35K FLUORESCENT	
EA		H.E WILLIAMS INC	50G-S24-332-FA12125-EQ-EBLW2/2*OS-277-GASKET	93	277	CR	3-32W T8 35K FLUORESCENT	
F		TMS LIGHTING	GN912LN-1-2-RL-RL-CM	86	277	PN	1-70W METAL HALIDE	
G		TARGETTI	SPITFA-T6-060-34-7-4-3-3-Q/IC-P3GD/EV-JB2A-3/4/IC-CR	44	120/277	G	1-39W METAL HALIDE	
H		KIM	VRB	61	208	P	1-50W HIGH PRESSURE SODIUM	
J		DAYBRITE	2AVG332-LMNP-UNV-EBLN*OS-1/21	93	120/277	CR	3-32W T8 35K FLUORESCENT	
K		BARBICAN	BAR-1T5-IC-HS-6001 CAT CUT-OUT	57	277	WS	2-26W DTT 35K FLUORESCENT	(11)
L		H.E WILLIAMS INC	50F-S44-432-RA12187-EBLW2/2*OS-277	124	277	CR	4-32W T8 35K FLUORESCENT	
M		DAYBRITE	WB232CP-277-EBLN*OS-1/2	62	277	WS	2-32W T8 35K FLUORESCENT	
N		H.E WILLIAMS INC	82-8-432-WS11-VBY-2-EBLW2/2*OS-277	124	277	CS	4-32W T8 35K FLUORESCENT	
N1		H.E WILLIAMS INC	82-4-232-WS11-VBY-2-EBLW2*OS-277	62	277	CS	2-32W T8 35K FLUORESCENT	
P		BARBICAN	BAR-1T5-IL-HS-6001 DOG CUT-OUT	57	277	WS	2-26W DTT 35K FLUORESCENT	(11)
Q		FINELITE	S12ID-WCB-4-3T8-DC-91W-OPEN-FA50-277-FE-835/XPS/ECO-OS*LW	93	277	-	3-32W T8 35K FLUORESCENT	
R		BEGA	3041 P	28	277	WS	1-26W DTT 35K FLUORESCENT	
S		H.E WILLIAMS INC	76-4-232-EBLW2*OS-277	62	277	CS	2-32W T8 35K FLUORESCENT	
SA		H.E WILLIAMS INC	76-2-217-EBLW2*OS-277	33	277	CS	2-17W T8 35K FLUORESCENT	
T		VISIONAIRE LTG	AME-1/T3/150HPS/277/CC	173	277	P	1-150W HIGH PRESSURE SODIUM	(10)
T1		VISIONAIRE LTG	AME-1/T3/150HPS/277/CC	173	277	P	1-150W HIGH PRESSURE SODIUM	(10)
T2		VISIONAIRE LTG	AME-1/T3/150HPS/277/CC/LS	173	277	P	1-150W HIGH PRESSURE SODIUM	(10)
U		ZUMTOBEL	55D6108U-6113RC-9930	35	120/277	CR	1-32W TRT 35K FLUORESCENT	
V		ZUMTOBEL	55D6108D (LUTRON FDB) -6113RC-9930	35	120/277	CR	1-32W TRT 35K FLUORESCENT	
W		ZUMTOBEL	55D6108D (LUTRON FDB) -6113W-9930	35	120/277	CR	1-32W TRT 35K FLUORESCENT	
X		EMERGI-LITE	ECLXN46	5	120/277	U	FURNISHED WITH FIXTURE	
Y		KIRLIN	FRR-05032	35	120/277	CR	1-32W TRT 35K FLUORESCENT	
Z		BRUCK	STFAH-131260	50	120	WS	1-50W MR16 HALOGEN	
AA		INSIGHT LIGHTING	EXS-EAS-6-SAT832-277-2-TW-VS	93	277	WS	3-32W T8 35K FLUORESCENT	
AB		H.E WILLIAMS INC	25F-48-132-A12125-EBLN1*OS-277	32	277	-	1-32W T8 35K FLUORESCENT	
AB1		H.E WILLIAMS INC	25F-36-125-A12125-EBLN1*OS-277	27	277	-	1-25W T8 35K FLUORESCENT	
AB2		H.E WILLIAMS INC	25F-24-117-A12125-EBLN1*OS-277	22	277	-	1-17W T8 35K FLUORESCENT	
AC		ZUMTOBEL	BRR6N5D-1V426X24Q4-U-MS-GL-W	46	277	CR	1-42W 35K FLUORESCENT	
AD		H.E WILLIAMS INC	26-2-332U-GLD-EB2-277	93	277	CS	3-32W T8 35K FLUORESCENT	
AE		ZUMTOBEL	(14) 903-3-SH-TN TRACK PER PLAN 55083 WH-SA	1050	277	CS	14-75W PAR 30 HALOGEN	
AF		SHORELINE	913.5005.02	-	120	S	-	
AG		HUBBELL	LCC-26F8-3 (VERIFY COLOR)	28	120	WS	1-26W 35K FLUORESCENT	
AH		GARDCO	101-MT-70MH-277	86	277	WS	1-70W METAL HALIDE	
AJ		H.E WILLIAMS INC	50G-S24-232-FA12125-EQ-EBLW2 OS-277	62	277	CR	2-32W T8 35K FLUORESCENT	

MOUNTING TYPES:
WS-WALL SURFACE, WR-WALL RECESSED, CS-CEILING SURFACE, CR-CEILING RECESSED, CH-CHAIN, PN-PENDANT, U-UNIVERSAL, G-GROUND, P-POLE, UC-UNDER CABINET, T-TRACK, CB-CABLE, TR-TRELLIS, C-COVE

NOTES:

1. EXIT SIGN PROVIDED WITH EMERGENCY BATTERY PACK.
2. BATTERIES FOR USE IN EMERGENCY FIXTURES TO BE "10TA"
3. "10TA" BATTERIES USED IN FLUORESCENT DOWNLIGHTS TO BE CAPABLE OF PROVIDING A MINIMUM OF 1100 LUMENS & MUST BE WIRED FOR 2-LAMP PARALLEL OPERATION.
4. FOOTCANDLES CALCULATED IN EMERGENCY OPERATION ARE BASED ON SPECIFIED FIXTURES, AND SUBSTITUTIONS BY THE ELECTRICAL CONTRACTOR SHALL REQUIRE RE-CALCULATION.
5. PROVIDE LENGTHS AND CORNER SECTIONS AS INDICATED ON PLANS
6. VERIFY COUNT AND FINISHED DIMENSIONS IN CONTINUOUS RUN APPLICATION
7. WITH CUSTOM FRONT ANIMAL CUT-OUT. SEE ARCHITECTURAL DRAWINGS.
8. CONFIRM SATIN ALUMINUM HOUSING FINISH WITH ARCHITECT
9. TRACK PROVIDED WITH 8A / 960W CURRENT LIMITER.
10. REFER TO FIXTURE DETAIL ON SHEET E1.1
11. FIXTURE PROVIDED BY OWNER, INSTALLED BY ELECTRICAL CONTRACTOR
12. VERIFY COLOR WITH ARCHITECT

SWATT | MIERS ARCHITECTS

5845 Doyle Street,
Suite 104
Emeryville, CA 94608
Tel: 510 985 9779
Fax: 510 985 0116
www.swattmiers.com

Not for Construction

JAN 19 2010

PREVAILING WAGE JOB

BID SET

REGISTERED PROFESSIONAL ENGINEER
GERALD L. GRIFFIN
No. E015691
Exp. 06-30-10
ELECTRICAL
STATE OF CALIFORNIA

KRUSE & ASSOCIATES
12245 WORLD TRADE DRIVE, STE. A
SAN DIEGO, CALIFORNIA 92128
(858) 676-9776
FAX #676-9744

PALM SPRINGS ANIMAL CARE FACILITY

4575 E. MESQUITE AVE.
PALM SPRINGS, CA 92262

CITY OF PALM SPRINGS
PROJECT NO. CP. 07-24

APN: 680-020-010

Issue

Rev	Date	By	Description
1	11/23/09		BLDG. PERMIT SET
2	01/18/10		BID SET

Drawn By

Checked By

Job No.

Issue Date

Scale NTS

Reference North

Drawing Title

FIXTURE SCHEDULE

Sheet

E0.2

These plans, drawings and specifications are the property of Swatt | Miers Architects and may not be used or reused thereof in part or in whole without the express permission of Swatt | Miers Architects. All rights reserved. Copyright 2009 Swatt | Miers Architects