PUBLIC LANDSCAPE DIVISION

1. Current drawings show a drip irrigation system. Delete the drip system and modify the current system with like heads and other necessary components.

Reviewer: Dan Jensen, Planning Arborist
Supervisor: Walt Warriner, Community Forester

Office Hours: 6:00 AM – 4:00 PM
Telephone: (310) 458 – 8974

RESPONSE:

The City of Santa Monica will not allow overhead spray within 24” of hardscape (see attached page from the City standards).