Construction Request for Information (Article 72)

RFI # G

Project: James Madison Elementary School Modernization Project AZA 101103

From (Company): RC Construction

Contact Name: Jon Wollam

Phone #: 909-772-2654 Email or Fax #: jon.wollam@rcconstruction.com

Trade: Landscape/Irrigation

Date Submitted: 3/15/2012 Response Urgency:

Reference: (Please indicate the exact location in the plans or specs)

Sheet #: LP-1 Spec. #:

Dwg/Det. #: Page #:

Note #:

Reviewed by Inspector prior to submittal:

Question: *Plastic Edging*

Sheet LP-1 what is the size of the plastic edging? The plans only show one location for the plastic edging. Is that the only place that the plastic edging is required? Or does that show the typical installation of plastic edging between the turf and shrub planters? Please confirm.

Proposed Solution:

Cost Impact - **Potential Schedule Impact -**

Response: **By:** Bob Gomon - SQLA **Date Returned:** 3/20/2012

The plan shows the typical installation of plastic edging between the turf and shrub areas. Please use 1x6 size, see detail 4/LP-3.

Questions must be emailed to kcolby@adolphziemba.com or faxed to (818) 841-7782.