Construction Request for Information (Article 72)

RFI #
K

Project: James Madison Elementary School Modernization Project AZA 101103

From (Company): RC Construction
Contact Name: Jon Wollam
Phone #: 909-772-2654 Email or Fax #: jon.wollam@rcconstruction.com
Trade: Acoustical Ceilings
Date Submitted: 3/16/2012 Response Urgency:
Reference: (Please indicate the exact location in the plans or specs)
Sheet #: A7.1 Spec. #: 09510
Dwg/Det. #: Page #:
Note #:
Reviewed by Inspector prior to submittal:

Question: *T-Bar Ceiling Tiles*

The specifications lists Armstrong and USG as the acceptable manufacturers. The finish schedule lists Armstrong as manufacturer for both types of Acoustical Ceilings. In the description of suspended acoustical tile, Armstrong's Random Fissured tile is listed while in the color of the suspended acoustical tile USG's Radar 2310 tile is listed. These are not equivelent products. Please clarify which tile is to be used, and also if we can use the USG equivalents of the listed Armstrong Products.

Proposed Solution:

Cost Impact - **Potential Schedule Impact -**

Response: **By:** Kevin Colby - AZA **Date Returned:**

The product for the acoutical ceiling tiles for suspended T-bar ceilings should be Radar 2310 by USG.

Questions must be emailed to kcolby@adolphziemba.com or faxed to (818) 841-7782.