Construction Request for Information (Article 72)

RFI #
J

Project: James Madison Elementary School Modernization Project AZA 101103

From (Company): RC Construction
Contact Name: Jon Wollam
Phone #: 909-772-2654 Email or Fax #: jon.wollam@rcconstruction.com
Trade: Casework
Date Submitted: 3/15/2012 Response Urgency:
Reference: (Please indicate the exact location in the plans or specs)
Sheet #: A1.3 Spec. #:
Dwg/Det. #: 1 & 2 Page #:
Note #:
Reviewed by Inspector prior to submittal:
Question: *Clarify Cabinetry*

Missing Elevations
Room D03 - CR #21 South Wall. Has one extra cabinet than that of the other rooms - May be IDF, Please clarify.
Room E03 North/South wall. Are they the same/Sim as E02?

Proposed Solution:

Cost Impact - **Potential Schedule Impact -**

Response: **By:** Kevin Colby - AZA **Date Returned:** 3/19/2012

1. CR #21 (D03) will have the same cabinets as called out in CR #22 (D02).
2. The north & south walls of CR #26 (E03) have the same cabinets as called out in classroom #25 (E02)

Questions must be emailed to kcolby@adolphziemba.com or faxed to (818) 841-7782.