

ENLARGED ELECTRICAL ROOMS

SCALE: 1/8" = 1'-0"

POWER AND CONTROL CONDUITS FOR HVAC UNITS SHALL ROUTE THROUGH CURB, INSIDE UNIT.



ROOF ELECTRICAL PLAN

SCALE: 1/8" = 1'-0"

ROOSEVELT — PROJECT NO. 270.032

VOLTS 277/480, PHASE 3PH, 4W, MTG SURFACE — PANELBOARD HF1 — LOCATION ELECT. ROOM #9 — MAIN 400A/3P, BUS 400A

CKT	A	B	C	TYPE	BKR	OUTLET QUAN	DESCRIPTION
1	2936	----	----	M1	20/3	1	AC-33
3	----	2936	----	M1	--	-	--------
5	----	----	2936	M1	--	-	--------
7	2936	----	----	M1	20/3	1	AC-32
9	----	2936	----	M1	--	-	--------
11	----	----	2936	M1	--	-	--------
13	2936	----	----	M1	20/3	1	AC-31
15	----	2936	----	M1	--	-	--------
17	----	----	2936	M1	--	-	--------
19	2936	----	----	M1	20/3	1	AC-34
21	----	2936	----	M1	--	-	--------
23	----	----	2936	M1	--	-	--------
25	2936	----	----	M1	20/3	1	AC-35
27	----	2936	----	M1	--	-	--------
29	----	----	2936	M1	--	-	--------
31	----	----	----				PROVISION
33	----	----	----				PROVISION
35	----	----	----				PROVISION
37	----	----	----				PROVISION
39	----	----	----				PROVISION
41	----	----	----				PROVISION

CKT	A	B	C	TYPE	BKR	OUTLET QUAN	DESCRIPTION
2	2936	----	----	M1	20/3	1	AC-30
4	----	2936	----	M1	--	-	--------
6	----	----	2936	M1	--	-	--------
8	2936	----	----	M1	20/3	1	AC-29
10	----	2936	----	M1	--	-	--------
12	----	----	2936	M1	--	-	--------
14	4930	----	----	M1	100/3	1	*HF2 SUBFEED*
16	----	4311	----	M1	--	-	--------
18	----	----	2604	M1	--	-	--------
20	18496	----	----	G	175/3	1	*FDNR TRANSFORMER*
22	----	15184	----	G	--	-	SUBFEED
24	----	----	17580	G	--	-	--------
26	2936	----	----	M1	20/3	1	AC-36
28	----	2936	----	M1	--	-	--------
30	----	----	2936	M1	--	-	--------
32	----	----	----				PROVISION
34	----	----	----				PROVISION
36	----	----	----				PROVISION
38	----	----	----				PROVISION
40	----	----	----				PROVISION
42	----	----	----				PROVISION

CONNECTED: VA / AMPS
PHASE A = 46914 / 169
PHASE B = 42963 / 155
PHASE C = 43672 / 158
TOTAL = 133569 / 161

L.C.L. @ 125% = 102886
RECEPT. ( ) 10 VAA @ 50% = 0
KITCHEN @ 65% = 0
OTHER LOAD @ 100% = 51250
TOTAL VA = 154146
TOTAL AMPS = 185

LOAD TYPE: G - GENERAL (100%); L - L.C.L. (125%); R - RECEPTACLE (50%); (10 VAA @ 100%); K - KITCHEN (65%); M - MOTOR (100%); M1 - MOTOR (125%); X - X-RAY (100%); X1 - X-RAY (50%)

ROOSEVELT — PROJECT NO. 270.032

VOLTS 277/480, PHASE 3PH, 4W, MTG SURFACE — PANELBOARD ENF — LOCATION BUILDING F ROOM 9 — MAIN 100A/3P, BUS 100A

CKT	A	B	C	TYPE	BKR	OUTLET QUAN	DESCRIPTION
1	450	----	----	L	20/1	10	X1-BUILDING F EXT. EGRESS LTG.
3	----	450	----	L	20/1	10	BUILDING D EXT. EGRESS LTG.
5	----	----	450	L	20/1	10	BUILDING E EXT. EGRESS LTG.
7	----	----	----				SPARE
9	----	----	----				SPARE
11	----	----	----				SPARE
13	----	----	----				PROVISION
15	----	----	----				PROVISION
17	----	----	----				PROVISION
19	----	----	----				PROVISION
21	----	----	----				PROVISION
23	----	----	----				PROVISION

CKT	A	B	C	TYPE	BKR	OUTLET QUAN	DESCRIPTION
2	----	----	----		20/1		SPARE
4	----	----	----		20/1		SPARE
6	----	----	----		20/1		SPARE
8	----	----	----				PROVISION
10	----	----	----				PROVISION
12	----	----	----				PROVISION
14	----	----	----				PROVISION
16	----	----	----				PROVISION
18	----	----	----				PROVISION
20	----	----	----				PROVISION
22	----	----	----				PROVISION
24	----	----	----				PROVISION

CONNECTED: VA / AMPS
PHASE A = 450 / 2
PHASE B = 450 / 2
PHASE C = 450 / 2
TOTAL = 1350 / 2

L.C.L. @ 125% = 1688
RECEPT. ( ) 10 VAA @ 50% = 0
KITCHEN @ 65% = 0
OTHER LOAD @ 100% = 0
TOTAL VA = 1688
TOTAL AMPS = 2

LOAD TYPE: G - GENERAL (100%); L - L.C.L. (125%); R - RECEPTACLE (50%); (10 VAA @ 100%); K - KITCHEN (65%); M - MOTOR (100%); M1 - MOTOR (125%); X - X-RAY (100%); X1 - X-RAY (50%)

X1 - INDICATES CIRCUIT CONTROLLED BY MULTI-POLE RELAY OPERATED BY PHOTOCELL ON/PHOTOCELL OFF FUNCTION OF EXTERIOR LIGHTING CONTROLLER. MOUNT RELAY IN A SEPARATE BARRIERED COMPARTMENT.

ROOSEVELT — PROJECT NO. 270.032

VOLTS 277/480, PHASE 3PH, 4W, MTG SURFACE — PANELBOARD HF2 — LOCATION ELECT. ROOM #9 — MAIN L.G., BUS 100A

CKT	A	B	C	TYPE	BKR	OUTLET QUAN	DESCRIPTION
1	1302	----	----	L	20/1	14	CLASSROOM LTG.
3	----	1302	----	L	20/1	14	CLASSROOM LTG.
5	----	----	1302	L	20/1	14	CLASSROOM LTG.
7	1302	----	----	L	20/1	14	CLASSROOM LTG.
9	----	1302	----	L	20/1	14	CLASSROOM LTG.
11	----	----	----		20/1		SPARE
13	----	----	----		20/1		SPARE
15	----	----	----		20/1		SPARE
17	----	----	----		20/1		SPARE
19	----	----	----				PROVISION
21	----	----	----				PROVISION
23	----	----	----				PROVISION

CKT	A	B	C	TYPE	BKR	OUTLET QUAN	DESCRIPTION
2	1302	----	----	L	20/1	14	CLASSROOM LTG.
4	----	1302	----	L	20/1	14	CLASSROOM LTG.
6	----	----	1302	L	20/1	14	CLASSROOM LTG.
8	1024	----	----	L	20/1	16	CUSTODIAN/RR. LTG.
10	----	405	----	L	20/1	9	X2-EXTERIOR LTG.
12	----	----	1000	L	20/1	20	X2-WALKWAY LTG.
14	----	----	----		20/1		SPARE
16	----	----	----		20/1		SPARE
18	----	----	----				PROVISION
20	----	----	----				PROVISION
22	----	----	----				PROVISION
24	----	----	----				PROVISION

CONNECTED: VA / AMPS
PHASE A = 4930 / 18
PHASE B = 4311 / 16
PHASE C = 3604 / 13
TOTAL = 12845 / 15

L.C.L. @ 125% = 16056
RECEPT. ( ) 10 VAA @ 50% = 0
KITCHEN @ 65% = 0
OTHER LOAD @ 100% = 0
TOTAL VA = 16056
TOTAL AMPS = 19

LOAD TYPE: G - GENERAL (100%); L - L.C.L. (125%); R - RECEPTACLE (50%); (10 VAA @ 100%); K - KITCHEN (65%); M - MOTOR (100%); M1 - MOTOR (125%); X - X-RAY (100%); X1 - X-RAY (50%)

X2 ? INDICATES CIRCUIT CONTROLLED BY MULTI-POLE RELAY OPERATED BY PHOTOCELL ON / TIMECLOCK OFF FUNCTION OF THE ENERGY MANAGEMENT SYSTEM. MOUNT RELAY IN LIGHTING TERMINAL CABINET LCF.

ROOSEVELT — PROJECT NO. 270.032

VOLTS 120/208, PHASE 3PH, 4W, MTG SURFACE — PANELBOARD PF1 — LOCATION ELECT. ROOM #9 — MAIN 200A/3P, BUS 225A

CKT	A	B	C	TYPE	BKR	OUTLET QUAN	DESCRIPTION
1	680	----	----	R	20/1	2	CLASSROOM RECEPTS
3	----	680	----	R	20/1	2	CLASSROOM RECEPTS
5	----	----	1680	R	20/1	4	CLASSROOM RECEPTS
7	1680	----	----	R	20/1	4	CLASSROOM RECEPTS
9	----	680	----	R	20/1	2	CLASSROOM RECEPTS
11	----	----	680	R	20/1	2	CLASSROOM RECEPTS
13	1680	----	----	R	20/1	4	CLASSROOM RECEPTS
15	----	1680	----	R	20/1	4	CLASSROOM RECEPTS
17	----	----	680	R	20/1	2	CLASSROOM RECEPTS
19	680	----	----	R	20/1	2	CLASSROOM RECEPTS
21	----	1680	----	R	20/1	4	CLASSROOM RECEPTS
23	----	----	1680	R	20/1	4	CLASSROOM RECEPTS
25	680	----	----	R	20/1	2	CLASSROOM RECEPTS
27	----	680	----	R	20/1	2	CLASSROOM RECEPTS
29	----	----	1680	R	20/1	4	CLASSROOM RECEPTS
31	1680	----	----	R	20/1	4	CLASSROOM RECEPTS
33	----	----	----		20/1		SPARE
35	----	----	----		20/1		SPARE
37	----	----	----		20/1		SPARE
39	----	----	----				PROVISION
41	----	----	----				PROVISION

CKT	A	B	C	TYPE	BKR	OUTLET QUAN	DESCRIPTION
2	680	----	----	R	20/1	2	CLASSROOM RECEPTS
4	----	680	----	R	20/1	2	CLASSROOM RECEPTS
6	----	----	1680	R	20/1	4	CLASSROOM RECEPTS
8	1680	----	----	R	20/1	4	CLASSROOM RECEPTS
10	----	680	----	R	20/1	2	CLASSROOM RECEPTS
12	----	----	680	R	20/1	2	CLASSROOM RECEPTS
14	1680	----	----	R	20/1	4	CLASSROOM RECEPTS
16	----	1680	----	R	20/1	4	CLASSROOM RECEPTS
18	----	----	680	R	20/1	2	CLASSROOM RECEPTS
20	680	----	----	R	20/1	2	CLASSROOM RECEPTS
22	----	1680	----	R	20/1	4	CLASSROOM RECEPTS
24	----	----	1680	R	20/1	4	CLASSROOM RECEPTS
26	680	----	----	R	20/1	2	CLASSROOM RECEPTS
28	----	680	----	R	20/1	2	CLASSROOM RECEPTS
30	----	----	1680	R	20/1	4	CLASSROOM RECEPTS
32	1680	----	----	R	20/1	4	CLASSROOM RECEPTS
34	----	----	----		20/1		SPARE
36	----	----	----		20/1		SPARE
38	4296	----	----	G	125/3	1	PANELBOARD PF2
40	----	4384	----	G	--	-	--------
42	----	----	4780	G	--	-	--------

CONNECTED: VA / AMPS
PHASE A = 19456 / 154
PHASE B = 15184 / 127
PHASE C = 17580 / 147
TOTAL = 51220 / 142

L.C.L. @ 125% = 0
RECEPT. ( ) 10 VAA @ 50% = 23880
KITCHEN @ 65% = 0
OTHER LOAD @ 100% = 13460
TOTAL VA = 37340
TOTAL AMPS = 104

LOAD TYPE: G - GENERAL (100%); L - L.C.L. (125%); R - RECEPTACLE (50%); (10 VAA @ 100%); K - KITCHEN (65%); M - MOTOR (100%); M1 - MOTOR (125%); X - X-RAY (100%); X1 - X-RAY (50%)

ROOSEVELT — PROJECT NO. 270.032

VOLTS 120/208, PHASE 3PH, 4W, MTG SURFACE — PANELBOARD PF2 — LOCATION ELECT. ROOM #9 — MAIN 125A/3P, BUS 225A

CKT	A	B	C	TYPE	BKR	OUTLET QUAN	DESCRIPTION
1	680	----	----	G	20/1	1	HAND DRYERS
3	----	680	----	G	20/1	1	HAND DRYERS
5	----	----	1680	R	20/1	7	CONN. RECEPTS
7	500	----	----	G	20/1	1	#FIRE ALARM PANEL
9	----	500	----	G	20/1	1	*TIM*
11	----	----	500	G	20/1	1	*IDF1*
13	506	----	----	M1	20/1	1	EF-13
15	----	200	----	M	20/1	1	COND. PUMP
17	----	----	506	M1	20/1	1	EF-15
19	540	----	----	M	20/1	3	ROOF RECEPTS.
21	----	540	----	M	20/1	3	ROOF RECEPTS.
23	----	----	200	G	20/1	1	#FSR BELL
25	70	----	----	M	15/2	1	FC-5
27	----	70	----	M	--	-	--------
29	----	----	----				PROVISION
31	----	----	----				PROVISION
33	----	----	----				PROVISION
35	----	----	----				PROVISION
37	----	----	----				PROVISION
39	----	----	----				PROVISION
41	----	----	----				PROVISION

CKT	A	B	C	TYPE	BKR	OUTLET QUAN	DESCRIPTION
2	1000	----	----	G	20/1	1	HAND DRYERS
4	----	1000	----	G	20/1	1	HAND DRYERS
6	----	----	500	G	20/1	1	*CMX*
8	500	----	----	G	20/1	1	*IDF*
10	----	884	----	M1	20/2	1	CU-5
12	----	----	884	M1	--	-	--------
14	500	----	----	G	20/1	1	CP-1
16	----	510	----	M	20/1	1	EF-16
18	----	----	510	M	20/1	1	EF-17
20	----	----	----		20/1		SPARE
22	----	----	----		20/1		SPARE
24	----	----	----				PROVISION
26	----	----	----				PROVISION
28	----	----	----				PROVISION
30	----	----	----				PROVISION
32	----	----	----				PROVISION
34	----	----	----				PROVISION
36	----	----	----				PROVISION
38	----	----	----				PROVISION
40	----	----	----				PROVISION
42	----	----	----				PROVISION

CONNECTED: VA / AMPS
PHASE A = 4296 / 36
PHASE B = 4384 / 37
PHASE C = 4780 / 40
TOTAL = 13460 / 37

L.C.L. @ 125% = 3475
RECEPT. ( ) 10 VAA @ 50% = 2760
KITCHEN @ 65% = 0
OTHER LOAD @ 100% = 7920
TOTAL VA = 14135
TOTAL AMPS = 39

LOAD TYPE: G - GENERAL (100%); L - L.C.L. (125%); R - RECEPTACLE (50%); (10 VAA @ 100%); K - KITCHEN (65%); M - MOTOR (100%); M1 - MOTOR (125%); X - X-RAY (100%); X1 - X-RAY (50%)

* PROVIDE CIRCUIT BREAKER LOCK-ON DEVICE.

PLAN NOTES:

1. PROVIDE 6#12, 1#12 GRD-3/4"C. PROVIDE SEPARATE NEUTRAL CONDUCTORS FOR EACH BRANCH CIRCUIT INDICATED. CONTINUE GROUND CONDUCTOR THROUGH ENTIRE LENGTH OF RUN.
2. PROVIDE 4#12, 1#12 GRD-3/4"C. PROVIDE SEPARATE NEUTRAL CONDUCTORS FOR EACH BRANCH CIRCUIT INDICATED. CONTINUE GROUND CONDUCTOR THROUGH ENTIRE LENGTH OF RUN.
3. PROVIDE 3/4"C.O. TO *EMTC*.
4. PROVIDE 3/4"C. WITH INTERLOCKING CONTROL WIRING DOWN TO RESPECTIVE FAN COIL IN ACCORDANCE WITH EQUIPMENT MANUFACTURER'S REQUIREMENTS.
5. PROVIDE 3/4"C. WITH INTERLOCKING CONTROL WIRING TO RESPECTIVE HVAC UNIT.
6. PROVIDE 3/4"C. WITH CONTROL WIRING DOWN TO THERMOSTAT.
7. PROVIDE 2" CONDUIT TO THE ENERGY MANAGEMENT TERMINAL CABINET. COORDINATE INSTALLATION OF LIGHTING CONROLS, RELAYS ETC. WITH THE EMS INSTALLER AND IN ACCORDANCE WITH DIVISION 15 SPECIFICATIONS.

MECHANICAL EQUIPMENT GENERAL NOTES:

1. VERIFY EXACT LOCATION OF MECHANICAL EQUIPMENT WITH MECHANICAL CONTRACTOR PRIOR TO INSTALLATION OF CONDUIT.
2. ALL EQUIPMENT, DEVICES, SAFETY SWITCHES, JUNCTION BOXES CONNECTIONS, ETC. MOUNTED ON THE ROOF OR EXTERIOR SHALL BE WEATHERPROOF.
3. REFER TO MECHANICAL DRAWING CONTROL DIAGRAM FOR ALL SENSORS, TIME CLOCKS, RELAYS, TIMERS, STARTERS, LINE AND LOW VOLTAGE CONDUIT AND PROVIDE AS REQUIRED.
4. SAFETY SWITCHES SHALL BE HORSEPOWER RATED WITH CURRENT LIMITING FUSES, SIZED PER THE MANUFACTURER'S RECOMMENDATION. SWITCHES SHALL HAVE 'RK-1' FUSE REJECTION CLIPS.
5. ELECTRICAL PLANS DO NOT INDICATE MECHANICAL AND PLUMBING EQUIPMENT CONTROL. REFER TO MECHANICAL AND PLUMBING PLANS AND SPECIFICATIONS AND PROVIDE ALL CONDUIT, WIRE, J-BOXES, OUTLET BOXES, RELAY SWITCHES, TIMESWITCHES, CONTROL CIRCUITS, ETC. REQUIRED FOR A COMPLETE AND OPERABLE MECHANICAL AND PLUMBING INSTALLATION. ALL WIRE SHALL BE INSTALLED IN CODE SIZED CONDUIT.
6. LOCATIONS OF SAFETY SWITCHES AND CONNECTIONS FOR MECHANICAL AND PLUBING EQUIPMENT ARE SHOWN DIAGRAMMATICALLY. VERIFY ACTUAL LOCATIONS WITH EQUIPMENT SHOP DRAWINGS AND LOCATE SAFETY SWITCHES LOCATED TO PROVIDE CODE REQUIRED CLEARANCES AND ACCESS. SAFETY SWITCHES LOCATED ON THE ROOF SHALL BE MOUNTED 30" MINIMUM ABOVE THE ROOF. IF THE MOUNTING OF SWITCHES DIRECTLY TO MECHANICAL EQUIPMENT IS NOT POSSIBLE, PROVIDE ANGLE IRON SUPPORT BRACKETS BOLTED TO THE ROOF FRAMING.

ROOM TITLES

● ONE-HOUR SEPARATION

1. CLASSROOM
2. CLASSROOM
3. CLASSROOM
4. CLASSROOM
5. CLASSROOM
6. CLASSROOM
7. CLASSROOM
8. CLASSROOM
● 9. DATA ROOM
● 10. ELECTRICAL
● 11. CUSTODIAN
12. BOYS TOILET
13. GIRLS TOILET
14. STORAGE
15. UNISEX STAFF TOILET
16. UNISEX STAFF TOILET

KEYPLAN



LICENSED ARCHITECT — JAMES M. STROUD — C19098 — RENEWAL 09/28/ — STATE OF CALIFORNIA

REGISTERED PROFESSIONAL ENGINEER — STEPHEN R. ZAK — Exp. 06-30-12 — ELECTRICAL — STATE OF CALIFORNIA

FBA Engineering — Consulting Electrical Engineers — 3420 Ocean Park Blvd. #3050, Santa Monica, California 90405 — TEL: 310 450 6090 FAX: 310 450 3207 — EMAIL: info@fbaengineering.net — FBA # 270.032

REVISIONS	DATE
1	-
2	-
3	-
4	-
5	-
6	-
7	-

P S W C GROUP
ARCHITECTS / PLANNERS
1897 BUSINESS CENTER DR., SUITE 3, SAN BERNARDINO, CA. 92408
909/890-2233 FAX. 909/890-2844

ROOSEVELT II ELEMENTARY SCHOOL
SAN BERNARDINO CITY UNIFIED SCHOOL DISTRICT
1261 W. 16TH STREET, SAN BERNARDINO, CA.

BUILDING F
ROOF AND ENLARGED
ELECTRICAL ROOM PLANS

JOB NO. P5820 | DRAWN BY FBA | DATE 12/9/2011

E-F.3

RE-BID #F09-02 ROOSEVELT II (HENRY) E.S. NEW CONSTRUCTION BID ISSUANCE SET 12/09/11